

PRODUCT CHANGE NOTIFICATION

PCN-DC-XAMZ-13

Business Unit	Product Line Code	Type of Change	Action	Date of issue
DC	AAA	Mechanical	Notify Distributors and Field	3/22/2013

The following Phoenix Contact products have been modified. Existing specifications will be met or exceeded. Please review and acknowledge this document and inform your personnel as needed.

Description of Change:

We are going to switch the insulation material for the 10- to 12-pole PC(V) 4 housings from PA to PBT. The reason is for the optimization of production. The CTI value will change from PA with 600 to 225 for PBT. Certifications and any further technical data (for example the voltage) are not affected by this change. Depending on the inventory and number of positions, both versions will be delivered in parallel during the conversion phase.

Warranty Information:

N/A

Stock Status

Can existing stock still be used? Y

Is mixture of stock acceptable? N

Transaction Dates:

Date modification goes into effect from Germany: 11/3/2012

Expected first shipment (from Phoenix Contact) of the modified product(s): 3/13/2013

PRODUCT CHANGE NOTIFICATION

Should you have any issues with the timeline or content of this change, please contact Phoenix Contact using the contact information below. Customers should acknowledge receipt of the PCN within 30 days of delivery of the PCN; provided, however that the failure to acknowledge receipt does not affect the product change or the effective date thereof.

Contact Info:

ANDREW BOGACZYK
(800)888-7388x3075
abogaczyk@phoenixcon.com

Thank you,



Steve Barber, Product Marketing Manager

Part#	Type Description
1801169	PCV 4/10-G-7.62 BK
1804768	PCV 4/10-G-7,62
1804784	PCV 4/12-G-7,62
1804878	PC 4/10-G-7,62
1804881	PC 4/11-G-7,62
1804894	PC 4/12-G-7,62
1927056	PC 4/10-G-7,62 BK