

1 Products affected

Product hierarchy no. *			Part no.	SBU	Type / Description	Customer part no.
SBU	PG	PUG	Type			
02	007	015	0000002427	See list below	Connectors	5088
02	007	015	0000002425	See list below	Connectors	5086
02	007	015	0000002424	See list below	Connectors	5084
02	007	015	0000002426	See list below	Connectors	5083

*SBU (2-digit) / PG (3-digit) / PUG (3-digit) / Type (10-digit)

List of part numbers affected				
6180.0009	6180.0003	6180.0016	6180.0021	6180.0024
6180.0031	6180.0032	6180.0034	6180.0035	6180.0004
6180.0005	6180.0030	3-107-775	3-108-036	6180.0006
6180.0013	6180.0015	6180.0038	6180.0007	6180.0042

2 Type of change


- Change of approval rating and marking according to UL/CSA 60320-1 Standard

3 Detailed description of change

- 5083: Change of approval rating from "2.5 A / 250 V" to "7A 125VAC for cURus"
- 5083: Change of VDE approval mark position
- 5083: Change of approval marking from "cCSAus" to "cURus"
- 5084: Change of approval rating from "7 A / 250 V" to "7A 125VAC for cURus"
- 5086: Change of approval rating from "7 A / 250 V" to "7A 125VAC for cURus"
- 5088: Change of approval rating from "4 A / 250 V" to "7A 125VAC and 2.5A 250VAC for cURus"

Old product appearance	New product appearance
<p>Old product appearance 5083</p>	<p>New product appearance 5083</p>
<p>Old product appearance 5084</p>	<p>New product appearance 5084</p>
<p>Old product appearance 5086</p>	<p>New product appearance 5086</p>
<p>Old product appearance 5088</p>	<p>New product appearance 5088</p>
Old label	New label

Product Change Notification					508X PCN		
owner	creation date	release date	released by	change order no	rev	page	D10-042-013
lokhanze	13.03.2020	18.03.2020	muehlema	2019583	B	1 of 2	



4 Reason of change

- Standard update UL/CSA 60320-1.

5 Release date

The change has been rolled-out starting ww 41/2019 and lasts approx. 8 months depending on the stock variant.

6 Impact of change and recommended action

Form	Yes	No action required, change of approval markings only.
Fit	No	No change for dimension
Function	Yes	Verify the new rating according to Standard impacts your application.
Manufacturing	No	No change for manufacturing site
Label	Yes	No action required, new packaging label.
Packaging	No	No change in packaging

7 Reference Documents / Attachments

Kind of document	Remarks
5083	
5084	
5086	
5088	

Product Change Notification					508X PCN		
owner	creation date	release date	released by	change order no	rev	page	D10-042-013
lokhanze	13.03.2020	18.03.2020	muehlema	2019583	B	2 of 2	